



# ATTESTATION

## of conformity with European Directives

**BV LCIE CHINA Number** N° 2566AS04BXHX59354

**Product** AC Contactor

**Reference** CJX2i-40, CJX2s-40, CJX2i-50, CJX2s-50, CJX2i-65, CJX2s-65

**Trademark** CNC

**Issued to** Zhejiang Changcheng Trading Co.,Ltd.

**Address** No. 66, Huachi Road, Yanjiang Industrial Area, BeiBaixiang Town, Yueqing City, Wenzhou City, 325603, Zhejiang Province, China

**Manufacturer** CNC Electric Group Co., Ltd.

**Address** No. 66, Huachi Road, Yanjiang Industrial Area, BeiBaixiang Town, Yueqing City, Wenzhou City, 325603, Zhejiang Province, China

Number of poles: 3P; Ue: 220/230/380/400/660/690V~; 50/60Hz

Us: 440V, 415V, 380/400V, 240V, 220/230V, 127V, 110V, 48V, 36V, 24V AC

**Technical characteristics**

| Utilization category | Ue                | Ie                |                   |                   |
|----------------------|-------------------|-------------------|-------------------|-------------------|
|                      |                   | CJX2i-40/CJX2s-40 | CJX2i-50/CJX2s-50 | CJX2i-65/CJX2s-65 |
| AC-3                 | 660/690V~         | 34A               | 39A               | 42A               |
|                      | 220/230/380/400V~ | 40A               | 50A               | 65A               |
| AC-4                 | 660/690V~         | 9A                | 12A               | 14A               |
|                      | 220/230/380/400V~ | 18,5A             | 24A               | 28A               |

Ith: 50A(CJX2i-40/CJX2s-40); 60A(CJX2i-50/CJX2s-50); 80A(CJX2i-65/CJX2s-65)

Ui= 690V Uimp=6kV

The submitted sample of the above equipment has been tested according to following European Directive and following standards:

**LVD Directive 2014/35/EU**

| Standards   | Report number            | Report date |
|---|--------------------------|-------------|
| EN 60947-1:2007 + A1:2011 + A2:2014<br>EN IEC 60947-4-1:2019<br>EN 60947-5-1:2017 | B240164-01<br>B240164-02 | 01/04/2025  |

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

**Shanghai (P.R. China), April 18<sup>th</sup>, 2025.**

**Product Line Manager**

Charlie Chen

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document is related to the tested specimen of the described electrical sample.